

(2) 200 HP, (3) SIZE 5, (3) SIZE 4 (2) SIZE 1, FURNAS MOTOR CONTROL CENTER (MCC)

VERTICAL SECTION #1 - 5 HIGH

COMPARTMENT #1
INCOMING

COMPARTMENT #2
(2) 30 AMP FUSED DISCONNECTS

COMPARTMENT #3
(2) 30 AMP FUSED DISCONNECTS

COMPARTMENT #4
(2) 30 AMP FUSED DISCONNECTS

COMPARTMENT #5
EMPTY

VERTICAL SECTION #2 - 3 HIGH

COMPARTMENT #1
10 AMP FUSED DISCONNECT
SIZE 1 FVNR STARTER

COMPARTMENT #2
60 AMP FUSED DISCONNECT

COMPARTMENT #3
175 AMP FUSED DISCONNECT
FURNACE SIZE 4 FVNR STARTER
CAT# 14JB321*71

VERTICAL SECTION #3 - 3 HIGH

COMPARTMENT #1
12 AMP FUSED DISCONNECT
SIZE 1 FVNR STARTER

COMPARTMENT #2

CASEY

www.caseyusa.com

275 Kappa Drive, Pittsburgh, PA 15209 • Phone: (412) 963-1111 Fax: (412) 963-0808 •

100 AMP FUSED DISCONNECT

COMPARTMENT #3

175A FUSED DISCONNECT
FURNAS SIZE 4, FVNR STARTER
CAT# 14JB321*71

VERTICAL SECTION #4 - 3 HIGH

COMPARTMENT #1

12 AMP FUSED DISCONNECT
SIZE 1 FVNR STARTER

COMPARTMENT #2

100 AMP FUSED DISCONNECT

COMPARTMENT #3

175A FUSED DISCONNECT
FURNAS SIZE 4, FVNR STARTER
CAT# 14JB321*71

VERTICAL SECTION #5

COMPARTMENT #1

400 AMP MOLDED CASE DISCONNECT
(3) 300 AMP FUSES
200 HP NORDIC SOLID STATE REDUCED VOLTAGE STARTER CAT#26A34V00
(3) 300:5 CT'S

VERTICAL SECTION #6

COMPARTMENT #1

400 AMP MOLDED CASE DISCONNECT
(3) 300 AMP FUSES
200 HP NORDIC SOLID STATE REDUCED VOLTAGE STARTER CAT#26A34V00
(3) 300:5 CT'S

INVENTORY ID: 113123-000-00

CASEY

www.caseyusa.com

275 Kappa Drive, Pittsburgh, PA 15209 • Phone: (412) 963-1111 Fax: (412) 963-0808 •