

**(3) 600 AMP, 14,400 VOLT, S & C FUSED DISCONNECTS  
WITH (5) VERTICAL SECTIONS  
PREVIOUSLY USED ON 2,400 VOLT**

**VERTICAL SECTION #1 - CABLE ENTRY**

- (3) CT'S GE 600/5
- (2) PT'S 750/500 KVA 30 DEGREE C/55 DEGREE C, 2400 V  
20:1 CAT# 763421G25
- (3) FUSES 4.8KV 1/2 E AMP CAT 27000
- POWER LOGIC CIRCUIT MONITOR
- METER 0-10 AMPS
- EXTERNAL TEST STRIP
- 250,000 SHORT CIRUIT RATING
- ENCLOSURE CAT B
- 600 AMP BUSS

**VERTICAL SECTION #2**

- S&C 14.4-17KV DISCONNECT SWITCH CAT# 255222R1-G3W  
600 AMP CONTINUOUS, MOMENTARY RMS 40.000
- (6) 300E FUSES (2 PER PHASE), TYPE 5S, CAT#86641R2,  
7.2 - 8.3 KV, REFILL UNIT SM-5
- KEY LOCK

**VERTICAL SECTION #3 - BUSS TRANSITION**

- VERTICAL BUSS - 120" W X 36" 48" D

**VERTICAL SECTION #4**

- S&C 14.4 - 17 KV DISCONNECT SWITCH CAT# 255222R1-G3, 600 AMP  
CONTINUOUS, MOMENTARY RMS 40.000
- (3) 250E FUSES, TYPE 5S, CAT#86641RS, 7.25 8.3 KV, REFILL UNIT SM-5  
0 -10 AMP METER ON DOOR
- KEY LOCK

**VERTICAL SECTION #5**

- S&C 14.4 - 17 KV DISCONNECT SWITCH CAT# 255222R1-G3, 600 AMP  
CONTINUOUS, MOMENTARY RMS 40.000
- (3) 250E FUSES, TYPE 5S, CAT#866414S, 7.25 8.3 KV, REFILL UNIT SM-5  
0 -10 AMP METER ON DOOR KEY LOCK

**INVENTORY ID: 115266-001, 115266-002, 115266-003, 115266-004, 115266-005**

