

**7200 VOLT GENERAL ELECTRIC VACUUM BREAKERS  
WITH (13) 1200 AMP AND (3) 2000 AMP POWER VAC VBI-7.2-500-2  
(13) 2-HIGH VERTICAL CUBICALS  
250 VOLT DC CLOSE AND TRIP**

**VERTICAL SECTION #1 - 2 HIGH**

COMPARTMENT #1

- \* PILOT WIRE RELAY GENERAL ELECTRIC CAT# 12CPD11D1A
- \* WATT-HOUR METER
- \* (2) WESTINGHOUSE OVER-CURRENT RELAY CAT# 1875572
- \* (1) WESTINGHOUSE OVER-CURRENT RELAY CAT# 7743236R10
- \* 0-1200 AMMETER
- \* 0-15 MEGA METER
- \* 0-7000 KVARs METER
- \* CONTROL SELECTOR SWITCH
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

COMPARTMENT #2

- \* (3) 0-300 AMMETER
- \* 0-3500 KILOWATT METER
- \* (3) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 125FC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #2 - 2 HIGH**

COMPARTMENT #1

- \* (4) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 125FSC153B8A
- \* (3) 0-400 AMMETER
- \* 0-500 KILOWATT METER
- \* (3) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 125FC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

COMPARTMENT #2

- \* (3) 0-400 AMMETER
- \* 0-500 KILOWATT METER
- \* (4) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 125FSC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #3 - 2 HIGH**

COMPARTMENT #1

- \* (4) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 12FSC153B8A
- \* (3) 0-300 AMMETER
- \* 0-500 KILOWATT METER

- \* (3) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 125FC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER
- COMPARTMENT #2
- \* (3) 0-300 AMMETER
- \* 0-3500 KILOWATT METER
- \* (4) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 12FSC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #4 - 2 HIGH**

COMPARTMENT #1

- \* PANAL ARM PANEL
- \* GENERAL ELECTRIC KILOWATT HOUR METER
- \* 0-9000 VOLT METER

COMPARTMENT #2

- \* CIRCUIT SELECTOR SWITCH
- \* (3) 0-2000 AMMETERS
- \* 0-24 MEGA WATT METER
- \* 0-12 MVARs METER
- \* 2000 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #5 - 2 HIGH**

COMPARTMENT #1

- \* (4) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 12FSC153A1A
- \* (3) 0-2000 AMMETER
- \* SYNC SWITCH
- \* CONTROL SELECTOR SWITCH
- \* 2000 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

COMPARTMENT #2

- \* TEST DEVICE STORAGE
- \* 0-50 AMMETER

**VERTICAL SECTION #6 - 2 HIGH**

COMPARTMENT #1

- \* PANAL ARM PANEL
- \* GENERAL ELECTRIC WATT HOUR METER
- \* 0-9000 VOLT METER
- \* CIRCUIT SELECTOR SWITCH

COMPARTMENT #2

- \* (3) 0-2000 AMMETER
- \* 0-24 MEGA WATT METER
- \* 0-24 MVARs METER
- \* (4) OVER CURRENT RELAYS GENERAL ELECTRIC CAT# 12FSC153A1A

\* 2000 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #7 - 2 HIGH**

COMPARTMENT #1

\* EMPTY

COMPARTMENT #2

- \* (3) 0-400 AMMETER
- \* 0-5000 KILOWATT METER
- \* MEGA WATT METER
- \* GE LOADPAK IV POWER MONITOR MODULE
- \* (3) DIFFERENT RELAYS GE CAT# 12CFD2282A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #8 - 2 HIGH**

COMPARTMENT #1

- \* (4) OVERCURRENT RELAYS GE CAT# 12FSC153B8A
- \* (3) 0-300 AMMETER
- \* 0-3500 KILOWATT METER
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

COMPARTMENT #2

- \* (3) 0-300 AMMETER
- \* 0-3500 KILOWATT METER
- \* (4) OVERCURRENT RELAYS GE CAT# 12FSC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #9 - 2 HIGH**

COMPARTMENT #1

- \* (3) 0-400 AMMETER
- \* 0-5000 KILOWATT METER
- \* (4) OVERCURRENT RELAYS GE CAT# 12FSC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #10 - 2 HIGH**

COMPARTMENT #1

- \* PILOT WIRE RELAY GENERAL ELECTRIC CAT# 12CDD11D1A
- \* WATT HOUR METER
- \* (2) WESTINGHOUSE OVER CURRENT RELAYS CAT# 1875572
- \* (1) WESTINGHOUSE OVER CURRENT RELAYS CAT# 7743236R10
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

COMPARTMENT #2

- \* (3) 0-400 AMMETER

- \* 0-3500 KILOWATT METER
- \* (3) OVERCURRENT RELAYS GE CAT# 125FC153B8A
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #11 - 2 HIGH**

COMPARTMENT #1

- \* (3) DIFFERENTIAL RELAYS GENERAL ELECTRIC CAT# 12CFD2282A
- \* WATT HOUR METER
- \* LOAD TRAK IV POWER MONITOR MODULE
- \* (3) 0-400 AMMETERS
- \* 0-5000 KILOWATT METER
- \* LOCKOUT RELAY
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

COMPARTMENT #2

- \* (3) DIFFERENTIAL RELAYS GENERAL ELECTRIC CAT# 12CFD2282A
- \* WATT HOUR METER
- \* LOAD TRAK IV POWER MONITOR MODULE
- \* (3) 0-400 AMMETERS
- \* 0-5000 KILOWATT METER
- \* LOCKOUT RELAY
- \* 1200 AMP VB1 7.2-500-2 E/O VACUUM BREAKER

**VERTICAL SECTION #12 - 2 HIGH**

COMPARTMENT #1

- \* (10) BREAKER TRY/CLOSE SWITCHES

COMPARTMENT #2

- \* LOCKOUT RELAY
- \* (3) DIFFERENTIAL RELAYS GENERAL ELECTRIC CAT# 12CFD2282A
- \* UNDER VOLTAGE RELAY GENERAL ELECTRIC CAT# 12SBD11B1A

**VERTICAL SECTION #13 - 2 HIGH**

COMPARTMENT #1

- \* (8) BREAKER TRIP CLOSE SWITCHES

COMPARTMENT #2

- \* LOCKOUT RELAY
- \* (3) DIFFERENTIAL RELAYS GENERAL ELECTRIC CAT# 12CFD2282A
- \* UNDER VOLTAGE RELAY GENERAL ELECTRIC CAT# 12SBD11B1A

DIMENSIONS: EACH VERTICAL 36" W X 94" D X 95" H



INVENTORY ID: 116985-000-00